

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION**  
**CERTIFICATE**

No. 541Date: 08/03/22

It is certified that an inspection team headed Rajesh Kumar Chemist (Name of Officers with designation) from Public Health Division, Bihar Sharif (Name of Department/Office) inspected the Nalanda Heritage School, Nirpur road, Near Mahabodhi College Nalanda, Bihar 80111 (Name & Address of the School) on 28.02.2022 and found that the Nalanda Heritage School (Name of School) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of six months.

Signature with Seal: \_\_\_\_\_

Name: RAMA SHANKAR SINGHDesignation: Quality Manager  
DLWTL, Bihar Sharif

To,

Nalanda Heritage School

Nirpur Road, Near Mahabodhi

College, Nalanda, Bihar, 803111

(Name &amp; Address of the Institution)

*Arjun*  
*Arjun*  
**Manager**  
Nalanda Heritage School  
Nirpur Road, Nalanda

*Chauhan*  
**PRINCIPAL**  
NALANDA HERITAGE SCHOOL  
NIRPUR ROAD, NALANDA-BIHAR  
PIN-803111

**Government of Bihar  
Public Health Engineering Department**

**Water Quality Report**

District Name: Nalanda      Division Name: Public Health Division, Biharsharif & Hilsa      Sample Collection date : - 26.02.2022      Format: I  
 Sample Collected by : - LAKSHYA AHLAWAT

Sl. No.	Block	Panchayat	Village	Name of Habitation	Ward No,	Location of Source	Test result													Source of Water			
							pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO <sub>3</sub>	SO <sub>4</sub>	F		T.Coli		
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22		
1	Silao	Nagar Panchayat Nalanda	Jagdishpur	Jagdishpur		Nalanda Heritage School	7.59	0.15	820	530	220	56	20	70	240	0.07	1.20	9.5	0.92	<1.1		Tube Well	
Desirable Limit*							6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	45	200	1.0	-	-	-	
Permissible Limit* in absence of alternate source							NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	**	-	-	-

*Rajesh Kumar*  
08/03/2022  
Chemist

Public Health Division, Biharsharif      Nalanda

*Chemist*

Public Health Division  
Biharsharif (Nalanda)

*Umesh Ahlawat*

**Manager School**  
Nalanda Heritage School  
Nirpur Road, Nalanda

*Principal*

**PRINCIPAL**

**NALANDA HERITAGE SCHOOL**  
NIRPUR ROAD, NALANDA-BIHAR  
PIN-803111

**Government of Bihar**  
**Public Health Engineering Department**  
**Water Quality Report**

District Name: Nalanda      Division Name: Public Health Division, Bihar Sharif & Hilsa      Sample Collection date : - 26.02.2022      Format: I  
 Sample Collected by : - LAKSHYA AHLAWAT

Sl. No.	Block	Panchayat	Village	Name of Habitation	Ward No,	Location of Source	Test result													Source of Water	
							pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO <sub>3</sub>	SO <sub>4</sub>	F		T.Coli
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
1	Silao	Nagar Panchayat Nalanda	Jagdishpur	Jagdishpur		Nalanda Heritage School	6.76	0.09	30	20	10	4	2	5	9.5	0.01	0.21	0.34	0.16	<1.1	RO Water
Desirable Limit*							6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	45	200	1.0	-	-
Permissible Limit* in absence of alternate source							NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	**	-

*Rajesh Kumar*  
 26/03/2022  
 Chemist

Public Health Division, Bihar Sharif

Nalanda

Chemist

Public Health Division

Bihar Sharif (Nalanda)

*Lakshya Ahlawat*  
 Manager

Nalanda Heritage School  
 Nirpur Road, Nalanda

*Lakshya Ahlawat*  
 PRINCIPAL

NALANDA HERITAGE SCHOOL  
 NIRPUR ROAD, NALANDA-BIHAR  
 PIN-803111